



# Willows Fire Department Self Inspection Form

445 S Butte St, Willows Ca, 95988  
(530)934-3322 FAX (530)934-5959



**This Form is to be submitted by mail or in person to the fire department at:**

**445 S. Butte St, Willows Ca, 95988 by \_\_\_\_\_**

Address of inspected occupancy: \_\_\_\_\_ APT# \_\_\_\_\_

1. Have you moved, added or eliminated any walls within your business the past 12 months? Yes No
2. Fire extinguisher has been inspected in past 12 months? Yes No  
Month and Year: \_\_\_\_\_
3. There is 30" access to all electrical panels so they are easily assessable? Yes No
4. All circuit breakers are clearly labeled? Yes No
5. All electrical outlets and junctional boxes have cover plates? Yes No
6. Power Strips and electrical cords are being used properly and in good order? Yes No
7. All emergency lights and exits signs function when tested? Yes No
8. Exit corridors and aisles are clear of obstructions? Yes No
9. Exit doors are clear of obstructions? Yes No
10. Building address is clearly visible? Yes No
11. Combustible storage outside of building is orderly and not a threat? Yes No
12. Smoke detectors are present in all sleeping areas? Yes No
13. Smoke detectors are functioning and not more than 10 years old? Yes No
14. Carbon monoxide detector functioning and not more than 5 years old? Yes No
15. Fire protection/ detection devices are unobstructed and in good order? Yes No

**If you have any questions, please call (530)-934-3322**